



August 31, 2016

Prospective Bidders

Re: Addendum #1

Bid No. W2016-91-B

WYLIE SENIOR RECREATION CENTER PARKING LOT EXPANSION PROJECT

=====

Questions:

Q) What is the ratio of lime per sq. yd?

A) 41 lbs. of lime per square yard.

Q) Can the paving be poured at a 1in. or 2in. thicker depth in lieu of lime?

A) In lieu of lime, paving can be poured two inches thicker provided that the grade is ripped six inches deep and compacted to 95%, 0 to +4 on moisture.

Vendors who may have already submitted a bid and feel this addendum may change their bid price may pick up their bid and return it **prior to September 8, 2016 @ 3:00 PM CDT**. If picking up the bid is not feasible, any new bid submitted by your firm will supersede one previously submitted.

If you have any questions regarding this addendum, please contact the City of Wylie Purchasing Department, (972) 516-6131.

Acknowledge receipt of this addendum by initialing in the appropriate space on the Vendor Acknowledgment Page if you have not previously submitted a bid.